

## Voltage Dips And Interruptions Test Results


SHENZHEN EMTEK CO., LTD.

Applicant : <u>SHENZHEN KSTAR SCIENCE AND TECHNOLOGY CO., LTD.</u>		Test Date : <u>January 16, 2014</u>		
EUT : <u>Uninterruptible power systems</u>		Temperature : <u>22°C</u>		
M/N : <u>YDC3320S/H</u>		Humidity : <u>50%</u>		
Power Supply : <u>AC 380V/50Hz</u>		Test Engineer : <u>YU</u>		
Test Mode: Line mode				
Test Level % U <sub>T</sub>	Voltage Dips & Short Interruptions % U <sub>T</sub>	Duration (in periods)	Criterion <input type="checkbox"/> A <input checked="" type="checkbox"/> B <input type="checkbox"/> C <input type="checkbox"/> D	Result
0	100	0.5P	B	A
40	60	10P	B	A
70	30	25P	B	A
0	100	250P	B	B
Note: Test in 0%, 250P, light appears flicker, but can self-recovery.				

## 16. LOW FREQUENCY SIGNALS TEST

### 16.1. Block Diagram of Test Setup

#### 15.1.1 Block Diagram of the EUT



(EUT: Uninterruptible power systems)  
Note: Above test setup is worst case by pretest.

### 16.2. Test Standard

IEC 61000-2-2:2002, Performance: A

	Criterion A
External and internal indications and metering (LCD)	No change
Output characteristics (Load)	No change
Control signals to external devices (Signal line)	No change
Mode of operation	No change

### 16.3. Operating Condition of EUT

Same as Section 4.4, Except the test setup replaced by Section 16.1.


### 16.4. Test Results

PASS.

Please refer to following page.




## Low Frequency Signals Test Result

SHENZHEN EMTEK CO., LTD.

Applicant : <u>SHENZHEN KSTAR SCIENCE &amp; TECHNOLOGY CO., LTD.</u> EUT : <u>Uninterruptible power systems</u> M/N : <u>YDC3340H</u> Power Supply : <u>AC 380V/50Hz</u> Test Engineer : <u>KY</u>			Test Date : <u>September 05, 2014</u> Temperature : <u>21°C</u> Humidity : <u>50%</u> Test Mode : <u>Line mode</u> Actual Criterion : <u>A</u>	
Frequency Range (Hz)	Position	Strength	Result	Note
140	See Fig.1	10V(rms) Sinusoidal	A	/
160			A	/
200			A	/
240			A	/
280			A	/
320			A	/
360			A	/
Note  <p style="text-align: center;">Fig.1</p>			Test Equipment: 1. Isolation transformer Primary: Secondary=1:1 2. Signal Generator AC Source: 6530(Chroma)	

## Low Frequency Signals Test Result

SHENZHEN EMTEK CO., LTD.

Applicant : <u>SHENZHEN KSTAR SCIENCE AND TECHNOLOGY CO., LTD.</u> EUT : <u>Uninterruptible power systems</u> M/N : <u>YDC3320S/H</u> Power Supply : <u>AC 380V/50Hz</u> Test Engineer : <u>YU</u>		Test Date : <u>January 16, 2014</u> Temperature : <u>21°C</u> Humidity : <u>50%</u> Test Mode : <u>Line mode</u> Actual Criterion : <u>A</u>		
Frequency Range (Hz)	Position	Strength	Result	Note
140	See Fig.1	10V(rms) Sinusoidal	A	/
160			A	/
200			A	/
240			A	/
280			A	/
320			A	/
360			A	/
Note L1, L2, L3 ———  N ———  <div style="text-align: center; margin-top: 10px;">                       Fig.1                 </div>			Test Equipment: 3. Isolation transformer Primary: Secondary=1:1 4. Signal Generator AC Source: 6530(Chroma)	


## 17. TEST PHOTOGRAPH

### 17.1.Photos of Conducted Emission Measurement





17.2. Photo of Radiation Emission Measurement








17.3.Photo of Harmonic / Flicker Measurement



17.4. Photo of Electrostatic Discharge Test



17.5.Photo of RF Field Strength susceptibility Test



17.6.Photos of Electrical Fast Transient/Burst Test



17.7.Photo of Surge Test



17.8. Photo of Injected Currents Susceptibility Test



17.9. Photo of Magnetic Field Immunity Test



17.10.Photo of Voltage dips and interruption Test





17.11.Photo of Low Frequency Signals Test



## APPENDIX (Photos of EUT)











